

WATER QUALITY DATA 2016 | CPCB ENVIS

TABLE - 21.1: WATER QUALITY OF WATER INTAKE POINTS FOR VARIOUS TOWNS IN KARNATAKA - 2016

station code	Station Name	State Name	Temperature °C		Dissolved oxygen (mg/l)		pH		Conductivity (µmhos/cm)		B.O.D. (mg/l)		Nitrate-N + Nitrite-N (mg/l)		Faecal Coli form (MPN/100ml)		Total Coli form (MPN/100ml)	
			min	max	min	max	min	max	min	max	min	max	min	max	min	max	min	max
Water quality criteria					>4 mg/l		6.5-8.5				<3 mg/l				<2500MPN/100ml		<5000MPN/100ml	
3568	WATER SUPPLY INTAKE POINT TO SRIRANGAPATNA TOWN	KARNATAKA	22	27	5.7	8	7.1	8.5	138	368	1	2.8	0.1	0.4	140	390	630	1700
3569	WATER SUPPLY INTAKE POINT TO MANDYA TOWN	KARNATAKA	23	28	5.5	7.8	8.1	8.5	152	352	1	2.9	0.2	0.7	170	490	630	2400
3570	D/S OF KR NAGAR BRIDGE	KARNATAKA	21	31	4.9	7.7	7.5	8.5	120	768	1.6	3	0.1	0.8	45	940	320	3500
3572	WATER SUPPLY INTAKE POINT TO HUNSUR TOWN	KARNATAKA	20	32	5.4	7.8	7.2	8.5	112	580	1.1	3	0.2	0.6	110	430	700	1700
3574	WATER SUPPLY INTAKE POINT TO MADIKERI TOWN	KARNATAKA	21	32	6.2	8	6.9	8.5	54	84	0.9	1.6	0.1	0.5	45	130	200	460
3576	WATER SUPPLY INTAKE POINT TO MYSORE PUMP HOUSE	KARNATAKA	24	30	6.2	7.8	7.8	8.5	150	330	1	2.4	0.2	0.7	110	460	840	1700
3577	WATER SUPPLY INTAKE POINT TO T NARASIPURA	KARNATAKA	22	31	5	8	6.8	8.5	156	484	1	2.5	0.2	0.7	170	1200	1100	3500
3579	WATER SUPPLY INTAKE POINT AT KOLLEGALA DASANAPURA	KARNATAKA	25	30	5.8	7.9	7.4	8.5	178	470	1.1	2.9	0.1	0.8	130	940	840	2400
3580	WATER SUPPLY INTAKE POINT AT MADDUAR	KARNATAKA	22	27	5.3	7.6	8.1	8.5	176	464	1	3	0.2	1.2	130	790	630	3500
3581	WATER SUPPLY INTAKE POINT AT T K HALLI	KARNATAKA	22	28	5.9	7.4	8	8.5	178	462	1.2	3	0.2	0.5	170	940	940	2200

For more information visit: www.cpcbenvnis.nic.in